

**CITY OF TORRANCE, CALIFORNIA**

**PRE-BID INQUIRIES**

**for**

**ZAMPERINI FIELD SECURITY PROJECT, FEAP 616  
B2013-52**

Q1: Reference Sheets C-01, C-02: Construction Note 19 shows to install new pavement loop detectors. What line item would these loop detectors belong to?

[A1: Include the cost for the loop detectors under Bid Items 105 and 106.]

Q2: Reference Sheet E-D2, Detail 3: There is a detail for a small power panel. Where is this panel located? It shows 2" conduit stubbing up to it but there is no 2" conduit line items.

[A2: Disregard detail, it is not applicable.]

Q3: Reference Sheet E-GAC: There seems to be a new Cat-6 Cable going throughout an existing building. What line item would this go under?

[A3: Include the cost for Cat-6 cable under Bid Item 34 "Miscellaneous Security/IT Equipment.]

Q4: Reference Sheet E-GAC: Some of the Cat-6 Cable is shown to be in ¾" conduit and General Note 3 on this sheet states cable to be plenum in existing building. Is the Cat-6 in conduit and is this conduit accounted for in Bid Item 21 and 22?

[A4: Cat-6 cable is not installed in conduit unless required by installation condition. Include the cost for any required conduit under Bid Item 34 "Miscellaneous Security/IT Equipment.]

Q5: Reference Sheets E-06 & E-07: Does this bid item account for removal and replacement of 2,500 LF of 4#10 and 1#12 wires as shown on Sheets E-06 and E-07?

[A5: Include the cost for removal and replacement of 4#10 and 1#12 under Bid Item 24.]